



## Above Ceiling Inspection Form

Name of Building: \_\_\_\_\_

Floor: \_\_\_\_\_ Room/Area: \_\_\_\_\_ Location: \_\_\_\_\_

Inspected By: \_\_\_\_\_ Affiliation: \_\_\_\_\_

Inspection Activity:	Yes	No	N/A	Comments
1. Are fire-rated and smoke-rated barriers free from unsealed penetrations? <i>101-2012, 8.3.5.1</i>				
2. Are fire-rated barriers free from gypsum-board surface-mounted patches? <i>101-2012, 8.3.1.2</i>				
3. Are fire-rated barriers free from embedded pipe, duct, or electrical junction boxes? <i>101-2012, 8.3.5.6.3</i>				
4. Are fire-stop materials in place, properly installed and in good condition? <i>101-2012, 8.3.5.1</i>				
5. Is structural steel free from missing sprayed-on fire-proofing? <i>101-2012, 19.1.6.1</i>				
6. Are suspended ceiling tiles free from gaps, cracks, or holes? <i>13-2010, 8.1.1(3)</i>				
7. Are suspended ceiling tiles in place? <i>13-2010, 8.1.1(3)</i>				
8. Is the space free from combustible materials used for support in Type I & Type II buildings? <i>220-2012, 4.3.1</i>				
9. Is the space free from evidence of water damage, such as mold, mildew, or water stains?				
10. Is sprinkler piping & hangers free from supporting wires, cables, chains, duct, etc.? <i>25-2011, 5.2.2.2</i>				
11. Is sprinkler piping supported directly from the building? <i>13-2010, 9.2.1.3</i>				
12. Is medical gas piping marked with identification labels every 20-feet, and in every room? <i>99-2012, 5.1.11.1.2</i>				
13. Are fire-rated barriers free from plastic pipe penetrations, unless the fire-stop system is designed for that purpose? <i>101-2012, 8.3.5.5.1</i>				
14. Are wires, cables and cords prevented from laying on top of the ceiling?				
15. Are electrical junction boxes mounted securely to a structure, and have covers installed? <i>70-2011, 314.28</i>				
16. Is electrical wiring that is 120-volts and above properly protected and terminated in raceways or junction boxes? <i>70-2011, 517.80</i>				
17. Are electrical wires entering junction boxes protected from abrasion? <i>70-2011, 314.17</i>				
18. Is electrical conduit free from supporting wires, cables, or cords? <i>70-2011, 300.11</i>				
19. Has all abandoned fire alarm system cable been removed? <i>70-2011, 760.25</i>				

All "No" answers must be fully explained.

*Numbers in italics are NFPA code/standard reference*

Signature: \_\_\_\_\_ Date: \_\_\_\_\_ Work Order #: \_\_\_\_\_